

**JOINT TASK FORCE
PREVENTIVE MEDICINE DEPARTMENT**

ENVIRONMENTAL HEALTH AND SANITATION INSPECTION REPORT

JTF Preventive Medicine (b)(3):10 USC 130b,(b)(6)	Date of Inspection: 23-May-12
---	--------------------------------------

Facility: Camp Justice Location: Exterior Grounds and Interior Tents	Jurisdiction: <u>JTF AQ</u>
---	------------------------------------

Inspector(s):
 (b)(3):10 USC 130b,(b)(6)

Signature(s) (b)(3):10 USC 130b,(b)(6)

Facility Manager, OIC, or Person in Charge:
 (b)(3):10 USC 130b,(b)(6)

Signature: (b)(3):10 USC 130b,(b)(6)

Inspection Type:
 Routine Incident Driven Re-inspection

Inspection Result:
 Satisfactory
 Unsatisfactory [date of re-inspection:]

Number of Critical Deficiencies: 0
Number of Non-Critical Deficiencies: 0

Deficiency/Recommendations:

Deficiency	Recommendation
N/A Is this a critical deficiency: <input type="radio"/> Yes <input type="radio"/> No <input checked="" type="radio"/> N/A	N/A IAW:

Additional Comments:
 A water sample was taken from the female shower and the chlorine residual was below range. We will contact the JTF engineers so they can run the lines and we will come out and retest the water to get a better chlorine residual.

